



Standard Operating Procedures

Fire Prevention Services
Office of Campus Safety

The University of Texas at Austin

304 E. 24th Street, SER Suite 202, Austin, TX 78713

Issue Date: July 16, 2019

FPS-SOP-101-07

Revision Date:

SCOPING & APPLICATION

CROWD MANAGERS – NUMBER REQUIRED FOR EVENTS AND TRAINING REQUIREMENTS

The following information provides guidance for the number of CROWD MANAGERS required based on the type and location of an event and the training required for CROWD MANAGERS for assembly occupancy events at The University of Texas at Austin.

ASSEMBLY OCCUPANCY DEFINED

An assembly occupancy is defined as an occupancy that is:

- A. Used for a gathering of fifty (50) or more persons for deliberation, worship, entertainment, eating, drinking, amusement, awaiting transportation, or similar uses: or
- B. Used as a special amusement building, regardless of occupant load.

NUMBER OF CROWD MANAGERS REQUIRED FOR EVENTS IN AN ASSEMBLY OCCUPANCY

Crowd Managers shall be required for events in assembly occupancies as follows:

- A. Outdoor Events – a crowd manager shall be required for outdoor events with an occupant load of one thousand (1,000) or more people. Additional crowd managers shall be provided at a ratio of one (1) crowd manager for every two hundred fifty (250) occupants over one thousand (1,000).
- B. Indoor Events – a crowd manager shall be required for indoor events with an occupant load of two hundred fifty (250) or more people. Additional crowd managers shall be

provided at a ratio of one (1) crowd manager for every two hundred fifty (250) occupants over two hundred fifty (250).

1. The policy applies to the number of occupants expected at a single time, not the total occupants throughout the event.
 2. Crowd Managers are not required for classrooms with an occupancy greater than fifty (50).
- C. Tents – A crowd manager shall be required for events in tents with an occupant load of five hundred (500) or more people. Additional crowd managers shall be provided at a ratio of one (1) crowd manager for every two hundred fifty (250) occupants over five hundred (500).
1. If fuel-fired equipment (cooking, heating, etc.) will be located under the tent, the number of occupants requiring a CROWD MANAGER shall be two hundred fifty (250).

TRAINING REQUIREMENTS FOR CROWD MANAGERS

Training for CROWD MANAGERS shall meet one of the following requirements:

- A. Live training provided by Fire Prevention Services.
- B. On-line training provided by Fire Prevention Services.
- C. Training provided by third party services that have been approved by Fire Prevention Services

Crowd Manager training shall be required to be renewed every two (2) years.

END OF DOCUMENT